

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7160-1487:101

Page 1 of 1

CATEGORY: Cables-Others

LISTEE: Genesis Cable System, 7701 95th Street, Pleasant Prairie, WI 53158-2716
Contact: Orville Allen *(262) 947-0720 Fax (262) 947-0724*

DESIGN: Models Type CL2, CL2P, CL2R, CL3, CL3P, CL3R, CM, CMP, CMR and MP power limited circuit and communication cables.

Conductors: In accordance with the standard

Insulation: PVC Compound GPT-150, Foam PP, PE, HDPE or LDPE

Assembly: 2 to 12 insulated conductors

Shield (Optional): Metal or Aluminum polyester tape shield

Braid (Optional): Metal braid over cable core

Jacket: PVC compound GPT-45, Gitto/Global Corp., Grade GA-5033, GA-93016, GA-91-84.
Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, NEC Article 725 & 800, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type and UL label.

APPROVAL: Listed as power-limited circuit and communication cables.

*Rev. 06-10-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 19, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division